


## Kidde Recalls Fire Extinguishers with Plastic Handles Due to Failure to Discharge and Nozzle Detachment: One Death Reported

**28.9K**



## Kidde Recalls Fire Extinguishers with Plastic Handles Due to Failure to Discharge and Nozzle Detachment: One Death Reported

### Name of product:

Kidde fire extinguishers with plastic handles

### Hazard:

The fire extinguishers can become clogged or require excessive force to discharge and can fail to activate during a fire emergency. In addition, the nozzle can detach with enough force to pose an impact hazard.



### Remedy:

Replace

### Recall date:

November 2, 2017

**Units:** About 37.8 million (in addition, 2.7 million in Canada and 6,730 in Mexico)

### Consumer Contact:

Kidde toll-free at 855-271-0773 from 8:30 a.m. to 5 p.m. ET Monday through Friday, 9 a.m. to 3 p.m. ET Saturday and Sunday, or online at [www.kidde.com](http://www.kidde.com) and click on “Product Safety Recall” for more information.

<https://www.cpsc.gov/Recalls/2017/kidde-recalls-fire-extinguishers-with-plastic-handles-due-to-failure-to-discharge-and>